



PIPE COLLAR DETAIL  
NTS

NOTES

1. THIS PROCEDURE/DETAIL WILL ONLY BE USED WHEN A PREFAB REDUCTION IS NOT POSSIBLE.
2. CONCRETE FOR COLLAR WILL NOT BE PAID FOR DIRECTLY, BUT WILL BE CONSIDERED SUBSIDIARY TO THE VARIOUS OTHER BIDS.
3. CONCRETE SHALL BE 5 SACK 3000 PSI.

REVISIONS									
REVISIONS									
<b>CITY OF ARLINGTON, TEXAS</b>									
<b>PROJECT NUMBER</b> <b>PROJECT NAME</b> <b>( PROJECT LIMITS )</b>									
DATE:		SCALE:		SHEET		OF			
DESIGNED BY:		DRAWN BY:		CHECKED BY:					